

Consumer Confidence Report Certification of Distribution for 2025

PWS Name: **Village of Palmer**
Population Served: **472**

Account Number: **NE3112103**
County: **Merrick**

CCR Distribution and CCR paperwork submittal are due no later than July 1, 2026.

You must use one or more direct delivery method to reach every bill paying customer. Good Faith delivery methods must be used to reach non-bill paying customers. Systems are required to maintain copies of CCRs to be available upon public request.

Direct Delivery Methods (Must use at least one of these methods):

Please provide the date(s) CCRs were distributed on lines provided below

- Mail a paper copy of the CCR. (Distribution date: _____)
- Publish CCR. (Publish date: _____, Send in a copy of the newspaper clipping of the CCR with this Certification.)
- Mail notification that the CCR is available online at the Internet address below. (Posting date: _____)
http://_____ (The internet link must take the customer directly to the open CCR.)
- Email notification that the CCR is available online at the Internet address below. (Posting date: _____)
http://_____ (The internet link must take the customer directly to the open CCR.)
- Email CCR as an attachment or an embedded image in an email. (Distribution date: _____)
- Posting the CCR in public places. List the three (3) posting locations below. (Posting date: 3/13/26)
1) Village of Palmer 2) Primerica Bank 3) U.S. Postal Office (Palmer)
(Note: Public water systems serving a population of 500 or less may elect to distribute CCRs by posting only.)
- Electronic delivery method at the Internet address below. (Posting date: _____)
Please provide URL: http://_____

Good Faith Delivery methods (to reach people who do not receive bills)

Please provide the date(s) CCRs were distributed below with the corresponding methods:

- Mailing the CCR to people who receive mail, but do not receive bills. (Distribution date: _____)
- Advertising the availability of the CCR in news media. (Distribution date: _____)
- Delivering multiple copies to business addresses serving multiple persons. (Distribution date: _____)
- Delivering copies of the CCR to community organizations (such as local health departments). (Distribution date: _____)

If your system is a wholesale water system which sells water to consecutive water systems, please answer the following question:

Were consecutive systems notified? Yes ___ No ___ If yes, who? _____

The community water system named above hereby affirms that the Annual Water Quality Report (i.e., Consumer Confidence Report) has been distributed to customers (and appropriate notices of availability have been given) in accordance with Nebraska's Regulations Governing Public Water Supply Systems, Title 179 NAC14. Further, this certifies that the information contained in the report is correct and consistent with the compliance monitoring data received by Nebraska Department of Water, Environment, and Energy.

Certified By: **Name (Print) Collins Haag** Signature: Collins Haag WO License Number: 5218
Phone: 308-750-1010 Email: 55chaag@gmail.com Date: 3/13/26

TEST RESULTS

Microbiological	Highest Number of Positive Samples	MCL	MCLG	Likely Source of Contamination	Violations Present		
No Detected Results were Found in the Calendar Year of 2025							
Lead and Copper	Monitoring Period	90th Percentile	Range	Unit	AL	Sites Over AL	Likely Source of Contamination
COPPER, FREE	2021 - 2023	0.2805	0.0326 - 0.345	ppm	1.3	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.
LEAD	2021 - 2023	1.5	0 - 1.8	ppb	15	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.
Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination
ARSENIC	3/19/2024	5	0 - 5	ppb	10	0	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
BARIUM	8/12/2025	0.218	0.218	ppm	2	2	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
FLUORIDE	8/12/2025	0.476	0.476	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; Fertilizer discharge.
NITRATE-NITRITE	11/12/2025	2.63	0 - 2.63	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Disinfection Byproducts	Monitoring Period	Highest RAA	Range	Unit	MCL	MCLG	Likely Source of Contamination
TOTAL HALOACETIC ACIDS (HAA5)	1/1/2025 - 12/31/2025	4.06	4.06	ppb	60	0	By-product of drinking water disinfection.
THM	1/1/2025 - 12/31/2025	1.89	1.89	ppb	80	0	By-product of drinking water disinfection.
Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination
COMBINED RADIIUM (-226 & -228)	6/24/2024	1.08	0 - 1.08	pCi/L	5	0	Erosion of natural deposits
RADIUM-228	6/24/2024	1.08	0 - 1.08	ppb	5	0	Erosion of natural deposits
Unregulated Water Quality Data	Collection Date	Highest Value	Range	Unit	Secondary MCL		
NICKEL	12/16/2025	0.111	0 - 0.111	mg/L	0.1		
SULFATE	12/16/2025	183	16.5 - 183	mg/L	250		
Violation Type	Category	Analyte	Compliance Period				
No Violations Occurred in the Calendar Year of 2025							

During the 2025 calendar year, we had the below noted violation(s) of drinking water regulations.

There are no additional required health effects violation notices.

There are no additional required health effects violation notices.

The Village of Palmer lead service line inventory has been prepared and can be accessed here:

Village of Palmer